



**Hillsborough County
Florida**

Office of the County Administrator
Patricia G. Bean

BOARD OF COUNTY COMMISSIONERS

Kevin Beckner
Rose V. Ferlita
Ken Hagan
Al Higginbotham
Jim Norman
Mark Sharpe
Kevin White

ADMINISTRATORS

Lucia E. Garsys
Carl S. Harness
Eric R. Johnson
Michael S. Merrill
Manus J. O' Donnell
Edith M. Stewart

Oakview Estates PWS# 6291288 - This portion of the 2008 Water Quality Report includes the results of the water quality monitoring performed by Water Resource Services from January 1 through December 31, 2008

Dear Hillsborough County Water Resource Services Customer: The drinking water for your community is provided by the Plant City Water Department. Attached is a report from the Plant City Water Department that provides you with information on the quality of the water they provided you in 2008. In addition to the monitoring done by the City, the WRS Environmental Laboratory monitors the water in your distribution system for total coliform bacteria, lead, copper, and disinfection byproducts. The following table includes any of these contaminants detected in 2008.

Microbiological Contaminants

Contaminant and Unit of Measurement	Dates of Sampling	MCL Violation Y/N	Highest Number of Positive Samples in Any Month	MCLG	MCL	Likely Source of Contamination
Total Coliform Bacteria	April, May, June 2008	N	1	0	Presence of coliform bacteria in 1 sample collected during any month	Naturally present in the environment

Stage 1 Disinfectants and Disinfection By-Products

Disinfectant or Contaminant and Unit of Measurement	Dates of Sampling	MCL or MRDL Violation Y/N	Level Detected	Range of Results	MCLG or MRDLG	MCL or MRDL	Likely Source of Contamination
Chlorine (ppm)	Jan-Dec 2008	N	1.2	0.2 – 2.1	MRDLG = 4	MRDL = 4.0	Water additive used to control microbes
Haloacetic Acids (five) (HAA5) (ppb)	August 2008	N	28.41	22.26 - 28.41	N/A	MCL = 60	By-product of drinking water disinfection
TTHM (Total Trihalomethanes) (ppb)	August 2008	N	53.27	53.27 - 83.70	N/A	MCL=80	By-product of drinking water disinfection

Lead and Copper (Tap Water)

Contaminant and Unit of Measurement	Dates of Sampling	Action Level Violation Y/N	90 th Percentile Result	Number of sampling sites exceeding the Action Level	MCLG	Action Level	Likely Source of Contamination
Copper (Tap Water) (ppm)	July 2008	N	0.289	0	1.3	1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead (Tap Water) (ppb)	July 2008	N	1.025	0	0	15	Corrosion of household plumbing systems; erosion of natural deposits

For an explanation of the abbreviations used in this table, please refer to the attached report from Plant City. If you have any questions regarding the water quality results in this table, please contact the WRS Environmental Laboratory at 264-3887. If you have questions regarding the attached report from the Plant City Water Department, please call the numbers provided in their report. WRS Customer Service can answer questions about your water bill by calling 272-6680. If you have a water quality complaint, please call the WRS Water Quality Line at 264-3835, or for a water emergency please call 744-5600. Water is a precious resource; please use it wisely to preserve it for present and future generations.