



BOARD OF COUNTY COMMISSIONERS
 Kevin Beckner
 Victor D. Crist
 Ken Hagan
 Al Higginbotham
 Lesley "Les" Miller, Jr.
 Sandra L. Murman
 Mark Sharpe

Office of the County Administrator
 Michael S. Merrill

CHIEF ADMINISTRATIVE OFFICER
 Helene Marks
 CHIEF FINANCIAL ADMINISTRATOR
 Bonnie M. Wise
 DEPUTY COUNTY ADMINISTRATORS
 Lucia E. Garsys
 Sharon D. Subadan

Oakview Estates PWS 6291288 This report includes data collected from January 1 through December 31, 2010

Dear Customer: Although you are a customer of the Hillsborough County Public Utilities Department, your drinking water has been supplied by the City of Plant City since early 1998. Included is a report from the City of Plant City that provides you with information on the quality of their water supplied to you in 2010. In addition to the monitoring done by the City, Hillsborough County monitors the water in your subdivision for total coliform bacteria, lead, copper and disinfection by-products. This table summarizes the levels of these contaminants, if detected in your water:

Stage 1 Disinfectants and Disinfection By-Products

Disinfectant or Contaminant and Unit of Measurement	Dates of Sampling	MCL or MRDL Violation	Level Detected	Range of Results	MCLG or MRDLG	MCL or MRDL	Likely Source of Contamination
Chlorine (ppm)	Jan-Dec 2010	No	1.1	0.8 - 1.4	MRDLG = 4	MRDL = 4.0	Water additive used to control microbes
Haloacetic Acids (five) (HAA5) (ppb)	Aug, Dec 2010	No	29.8	24.7 - 34.9	N/A	MCL = 60	By-product of drinking water disinfection
TTHM (Total Trihalomethanes) (ppb)	Aug, Dec 2010	No	76.7	69.5 - 83.9	N/A	MCL = 80	By-product of drinking water disinfection

Lead and Copper (Tap Water)

Contaminant and Unit of Measurement	Dates of Sampling	Action Level Exceeded	90th Percentile Result	Number of Sampling Sites Exceeding the Action Level	MCLG	Action Level	Likely Source of Contamination
Copper (Tap Water) (ppm)	Jul 2008	No	0.289	0	1.3	1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead (Tap Water) (ppb)	Jul 2008	No	1.025	0	0	15	Corrosion of household plumbing systems; erosion of natural deposits

For an explanation of the abbreviations used in the above table, please refer to the water quality report included in this mailing. If you have any questions regarding the monitoring Hillsborough County performs on your water, please contact our Environmental Laboratory at (813) 264-3887. If you have other water quality questions or concerns, the included report from the Plant City Water Department provides additional contact information. Hillsborough County Public Utilities Department Customer Service, at (813) 272-6680, can answer questions you may have about your bill. If you have a water quality complaint, call (813) 264-3835. For an after-hours water-related emergency, call (813) 744-5600. We urge all our customers to use this precious resource wisely to preserve it for present and future generations.