



Hillsborough County Water Resources Department
Appendix B: Pre-approved Products and Materials

 Hillsborough County Florida		Optimal County Limit ☀	POTABLE WATER	RECLAIMED WATER	WASTEWATER (Gravity)	WASTEWATER (Force Main)	WASTEWATER (Pump Station)	Manufacturer	Part Name/ Model Number	Important Notes and Stipulations
Access Frames	Access Frames and Valve Boxes	No Limit	-	-	Yes	-	-	U.S. Foundry	USF 227-SQ	Model # 8015108 Specifies "Hillsborough County Florida, EST. 1834, Foundry, <u>SANITARY</u> " and Hillsborough County logo on cover (POR-15 Coating required for all wastewater service)
			Yes	Yes	-	Yes	-	U.S. Foundry	USF 227-AQ	Model 8015188 Specifies "Hillsborough County Florida, EST. 1834, Foundry, <u>AIR RELEASE</u> " and Hillsborough County logo on cover. (POR-15 coating required for sanitary sewer)
			-	-	-	-	Yes	U.S. Foundry	USF 105-M	LPSS use only. "SANITARY SEWER" on cover. (POR-15 coating required.)
			-	-	Yes	-	-	East Jordan Iron Works (EJ)	1071A-LO (Cover) 1227Z (Ring)	"Year, Hillsborough County Florida, Sanitary Sewer" and Hillsborough County logo on cover (POR-15 Coating required when Force Main dumps into Gravity)
			-	-	-	-	-			
	Manhole Cover and Cone Casting Grade Adjusting Rings	No Limit	-	-	Yes	-	-	Ladtech	Wedge (Conical)	Approved for Traffic & Non-traffic applications. Shall be installed using a butyl sealant meeting ASTM C-990 per mfg. instructions.
			Yes	Yes	Yes	Yes	-	U.S. Foundry	Type A: Steel Adjusting Rings	Use approved Manhole Frame and Cover Protective Paint for Force Mains dumping into Gravity or for Wastewater ARV
			-	-	-	-	-			
	Valve Box and Cover	No Limit	Yes	Yes	Yes	Yes	Yes	Tyler / Union	6850 Series	Screw Type With Base and Lid
			Yes	Yes	Yes	Yes	Yes	Sigma / Russell Pipe Company		Screw Type With Base and Lid
			Yes	Yes	Yes	Yes	Yes	Star Pipe Products		Screw Type With Base and Lid
			Yes	Yes	Yes	Yes	Yes	Bingham & Taylor	Series 4905	Screw Type with Base, Std & Heavy Lid, Skirt and Risers
	Wetwell Access and Frames (Hinged on discharge piping side)	No	-	-	-	-	Yes	Halliday Products, Inc	Series S-R	
			-	-	-	-	Yes	Water / Wastewater Systems, Inc.		Fabricated with water Dept. Approval
			-	-	-	-	-			



◊ - PRC approval of a product will not be given, or considered, as part of an active bid or bid review.
 ◊ - Where this list may conflict with the Technical Specifications, the Technical Specifications take precedence.
 ◊ - the use of these pre-approved products in some applications may require a Design Exception.
 ◊ - When deemed to be in the best interest of the County, the County reserves the right to:
 1) remove a product from this list without notice, and 2) limit the number of pre-approved products or manufacturers

**Hillsborough County Water Resources Department
Appendix B: Pre-approved Products and Materials**

 Hillsborough County Florida		Optimal County Limit ☀	POTABLE WATER	RECLAIMED WATER	WASTEWATER (Gravity)	WASTEWATER (Force Main)	WASTEWATER (Pump Station)	Manufacturer	Part Name/ Model Number	Important Notes and Stipulations
		☀								
Backflow Prevention, Etc.	Backflow Prevention Assemblies & Devices (For Hillsborough County owned & maintained assets)	No Limit	Yes	-	-	-	-	Apollo Valves (Conbraco)	RPLF4A	1/2" - 2" (Required Specs: RPZ, ASSE 1013, AWWA C511, NSF-61)
			Yes	-	-	-	-	Apollo Valves (Conbraco)	RP4A	2 1/2" - 10" (Required Specs: RPZ, ASSE 1013, AWWA C511, NSF-61)
			Yes	-	-	-	-	Wilkins (Zurn)	975XL2	3/4" - 2" (Required Specs: RPZ, ASSE 1013, AWWA C511, NSF-61)
			Yes	-	-	-	-	Wilkins (Zurn)	375	2" - 10" (Required specs: RPZ, Epoxy Coated DI, ASSE 1013, AWWA C511, NSF-61)
			Yes	-	-	-	-	Ford Meter Box Company INC	HHS 31-323-NL	5/8" x 3/4" (Required specs: ASSE 1024, NSF-61) (ONLY for Residential water service connections where there is an Auxiliary Water System, or contains another Potential Cross-connection)
			Yes	-	-	-	-	A.Y. McDonald	7411-3JE-43	NL - 3/4" swivel nut less saddle x FNPT (Required specs: ASSE 1024, NSF-61) (ONLY for residential services where there is auxiliary irrigation reclaim cross connection control)
			Yes	-	-	-	-	A.Y. McDonald	7411-3JE-54	NL - 1" swivel nut less saddle x FNPT (Required specs: ASSE 1024, NSF-61) (ONLY for Residential water service connections where there is an Auxiliary Water System, or contains another Potential Cross-connection)
	Casing Spacers	4	Yes	Yes	Yes	Yes	-	Cascade	CCS	Stainless Steel (8" to 48")
			Yes	Yes	Yes	Yes	-	GPT Industries	C12 G2	8" width min, place every 6 to 8ft of linear pipe run
			Yes	Yes	Yes	Yes	-	RACI Spacers North America		Sizes Greater than 33" require PUD Design Exception
	Marking Tape (4.5 mil Thickness & 2" Width minimum)	No Limit	Yes	-	-	-	-	Pro-Line Safety Products	Blue	
			-	-	-	Yes	-	Pro-Line Safety Products	Green	
			-	Yes	-	-	-	Pro-Line Safety Products	Purple	
			-	-	-	-	-			
	Flexible Wetwell & Manhole to Pipe Connectors	No Limit	-	-	Yes	-	-	A-Lok Products, Inc.	Z-Lok	
-			-	Yes	-	-	Trelleborg	Kor-N-Seal		
-			-	Yes	-	-	Press Seal Gasket	PSX Direct Drive		
-			-	-	-	-				



◊ - PRC approval of a product will not be given, or considered, as part of an active bid or bid review.
 ◊ - Where this list may conflict with the Technical Specifications, the Technical Specifications take precedence.
 ◊ - the use of these pre-approved products in some applications may require a Design Exception.
 ◊ - When deemed to be in the best interest of the County, the County reserves the right to:
 1) remove a product from this list without notice, and 2) limit the number of pre-approved products or manufacturers

Hillsborough County Public Utilities Department Appendix B: Pre-approved Products and Materials

		Optimal County Limit 	POTABLE WATER	RECLAIMED WATER	WASTEWATER (Gravity)	WASTEWATER (Force Main)	WASTEWATER (Pump Station)	Manufacturer	Part Name/ Model Number	Important Notes and Stipulations
			POTABLE WATER	RECLAIMED WATER	WASTEWATER (Gravity)	WASTEWATER (Force Main)	WASTEWATER (Pump Station)			
Fittings, Tapping Saddles & Service Saddles	Directional Change Fittings	No Limit	Yes	Yes	-	Yes	Yes	U.S. Pipe Company		Sewer-- Aprvd Ceramic Epoxy needed
			Yes	Yes	-	Yes	Yes	Sigma / Russell Pipe Company		Sewer-- Aprvd Ceramic Epoxy needed. Note: MJ Sleeves are not approved for use.
			Yes	Yes	-	Yes	Yes	American Ductile Iron Pipe Company		14" & Larger; Sewer--Ceramic Exoxy Interior
			Yes	Yes	-	Yes	Yes	Tyler/Union		Sewer-- Aprvd Ceramic Epoxy needed
			Yes	Yes	-	Yes	Yes	North American Cast Iron Products (NACIP)		Sewer-- Aprvd Ceramic Epoxy needed
			Yes	Yes	-	Yes	Yes	One-Bolt Inc.		Mfg Restraint included; Sewer-- Ceramic Epoxy Interior
			Yes	Yes	-	Yes	Yes	Star Pipe Products		Sewer-- Aprvd Ceramic Epoxy needed, Note: MJ Sleeves are not approved for use.
			Yes	Yes	-	Yes	Yes	Serampore Industries Private Ltd. (SIP)		Sewer-- Aprvd Ceramic Epoxy needed
	PVC for Laterals (SDR 26)	No Limit	-	-	Yes	-	-	Harrington Corp (HARCO)		Approved thru 8"
			-	-	Yes	-	-	Multi Fittings Corp		Approved thru 8"
			-	-	Yes	-	-	National Pipe & Plastics Inc		4" to 15"
			-	-	Yes	-	-	Royal Building Products		
			-	-	Yes	-	-	GPK Products		
	Service Saddles	No Limit	Yes	Yes	-	-	-	Smith-Blair (Sensus)	313	Epoxy coat DI body, dual bale
			Yes	Yes	-	-	-	Ford Meter Box Company INC	F-202	E-coat DI body, dual bale
-			-	-	Yes	-	Ford Meter Box Company INC	FS323-xxx-IP7-Q	4 to 12 inch pipe size Saddles, all stainless Steel components required for force main Air Release Valve Installations	
Yes			Yes	-	-	-	JCM Industries	402	Shop coat DI body, dual bale	
-			-	-	Yes	-	Continental Industries INC	PVC Super FastTap	3"-6", For LPSS use only	
Yes			Yes	-	-	-	JCM Industries	406	Epoxy coat DI body, dual SS Straps	
-			Yes	-	-	-	Cascade	CNS2	Epoxy coat DI body, dual SS Straps	
Yes			Yes	-	-	-	A.Y. McDonald	4826A	Epoxy coat DI body, dual straps	
Specialized Fitting Type Items	No Limit	Yes	Yes	-	Yes	-	Infact Corporation	Foster Adapter	* Must have Epoxy coating (10 mills thickness) * Must be Pre-Approved for use in Wastewater	
		-	-	-	-	-				


◊ - PRC approval of a product will not be given, or considered, as part of an active bid or bid review.
 ◊ - Where this list may conflict with the Technical Specifications, the Technical Specifications take precedence.
 ◊ - the use of these pre-approved products in some applications may require a Deign Exception.
 ◊ - When deemed to be in the best interest of the County, the County reserves the right to:
 1) remove a product from this list without notice, and 2) limit the number of pre-approved products or manufacturers

Hillsborough County Public Utilities Department Appendix B: Pre-approved Products and Materials

 Hillsborough County Florida		 Optimal County Limit					Manufacturer	Part Name/ Model Number	Important Notes and Stipulations			
		POTABLE WATER	RECLAIMED WATER	WASTEWATER (Gravity)	WASTEWATER (Force Main)	WASTEWATER (Pump Station)						
Fittings, Tapping Saddles & Service Saddles	Tapping Sleeve	Less Than Size-On Size Taps	No Limit	Ductile Iron (MJ ends x Flange Outlet)	Yes	Yes	-	Yes	-	American Flow Control	Series 2800	4"-16" (For Use on DI & CI)
				Fabricated SST (with flange outlet and wrap-around gasket)	Yes	Yes	-	Yes	-	Mueller Co.	H-615	4"-24", 4"-12" for PVC (For Use on PVC, DI, & CI)
				Fabricated Carbon Steel (Epoxy Coated, SST hdwe, with flange outlet, outlet seal gasket)	Yes	Yes	-	Yes	-	Tyler/Union		6"-12" (For use on DI & CI)
					Yes	Yes	-	Yes	-	Mueller Co.	H-304SS	4"-12" (For Use on PVC, AC, DI & CI)
					Yes	Yes	-	Yes	-	JCM Industries	432	4"-12" (For Use on PVC, AC, DI & CI)
				Yes	Yes	-	Yes	-	Cascade	CST-EX	4"-12" (For Use on PVC, AC, DI & CI)	
				Yes	Yes	-	Yes	-	Smith-Blair (Sensus)	622	4"-30" (For Use on PVC, DI, & CI)	
				Yes	Yes	-	Yes	-	JCM Industries	412 ESS	6"-30" (For Use on PVC, DI, & CI)	
				Yes	Yes	-	Yes	-	Ford Meter Box Company INC	FTSC	4"-30" (For Use on PVC, DI, & CI)	
				-	-	-	-	-				


- ◊ - PRC approval of a product will not be given, or considered, as part of an active bid or bid review.
- ◊ - Where this list may conflict with the Technical Specifications, the Technical Specifications take precedence.
- ◊ - the use of these pre-approved products in some applications may require a Design Exception.
- ◊ - When deemed to be in the best interest of the County, the County reserves the right to:
 - 1) remove a product from this list without notice, and 2) limit the number of pre-approved products or manufacturers

Hillsborough County Public Utilities Department Appendix B: Pre-approved Products and Materials

 Hillsborough County Florida		Optimal County Limit ☀	POTABLE WATER	RECLAIMED WATER	WASTEWATER (Gravity)	WASTEWATER (Force Main)	WASTEWATER (Pump Station)	Manufacturer	Part Name/ Model Number	Important Notes and Stipulations	
			Yes	Yes	Yes	Yes	Yes				
Flow Meters	With Double Check Backflow Meter	3/4"	No Limit	Yes	-	-	-	-	Neptune Technology Group	T10DC (Dual Check)	
	Residential Service Meters	5/8" X 3/4"	No Limit	Yes	Yes	-	-	-			
				Yes	Yes	-	-	-	Badger Meter Inc	Recordall Disk Series Model LP	
				Yes	Yes	-	-	-	Badger Meter Inc	Recordall Disk Series Model 25	
				Yes	Yes	-	-	-	Neptune Technology Group	T10	
				Yes	Yes	-	-	-	Sensus Metering Systems	SR11	
				-	-	-	-	-	Master Meter	BLMJ	
		1"	No Limit	Yes	Yes	-	-	-	Mueller Systems	452-IIS	
				Yes	Yes	-	-	-	Neptune Technology Group	T10	
				Yes	Yes	-	-	-	Sensus Metering Systems	SR11	
				Yes	Yes	-	-	-	Master Meter	BLMJ	


◊ - PRC approval of a product will not be given, or considered, as part of an active bid or bid review.
 ◊ - Where this list may conflict with the Technical Specifications, the Technical Specifications take precedence.
 ◊ - the use of these pre-approved products in some applications may require a Deign Exception.
 ◊ - When deemed to be in the best interest of the County, the County reserves the right to:
 1) remove a product from this list without notice, and 2) limit the number of pre-approved products or manufacturers

Hillsborough County Public Utilities Department Appendix B: Pre-approved Products and Materials

		Optimal County Limit ☀					Manufacturer	Part Name/ Model Number	Important Notes and Stipulations		
		POTABLE WATER	RECLAIMED WATER	WASTEWATER (Gravity)	WASTEWATER (Force Main)	WASTEWATER (Pump Station)					
Flow Meters	Small Commercial Service	1 1/2"	No Limit	Yes	Yes	-	-	-	Badger Meter Inc	Recordall Disk Series Model 120	(FL x FL)--> Requires flange adapter to convert to FIPxFIP
				Yes	Yes	-	-	-	Mueller Systems	562 IIS	(FL x FL)--> Requires flange adapter to convert to FIPxFIP
				Yes	-	-	-	-	Master Meter	Octave Ultrasonic	
				Yes	Yes	-	-	-	Neptune Technology Group	T10	(FL x FL)--> Requires flange adapter to convert to FIPxFIP
				Yes	Yes	-	-	-	Sensus Metering Systems	Omini T ²	(FL x FL)--> Requires flange adapter to convert to FIPxFIP
				-	-	-	-	-			
		2"	No Limit	Yes	Yes	-	-	-	Badger Meter INC	Recordall Disk Series Model 170	(FL x FL)--> Requires flange adapter to convert to FIPxFIP
				Yes	Yes	-	-	-	Mueller Systems	572 IIS	(FL x FL)--> Requires flange adapter to convert to FIPxFIP
				Yes	Yes	-	-	-	Neptune Technology Group	T10	(FL x FL)--> Requires flange adapter to convert to FIPxFIP
				Yes	Yes	-	-	-	Neptune Technology Group	HP Turbine	(FL x FL)--> Requires flange adapter to convert to FIPxFIP
				Yes	Yes	-	-	-	Badger Meter Inc	RecordAll-Turbo Series Model 200	(FL x FL)--> Requires flange adapter to convert to FIPxFIP
				Yes	Yes	-	-	-	Sensus Metering Systems	Omini T ²	(FL x FL)--> Requires flange adapter to convert to FIPxFIP
				Yes	Yes	-	-	-	Mueller Systems	MVR 160 (Turbine)	(FL x FL)--> Requires flange adapter to convert to FIPxFIP
				Yes	-	-	-	-	Master Meter	Octave Ultrasonic	


- ◊ - PRC approval of a product will not be given, or considered, as part of an active bid or bid review.
- ◊ - Where this list may conflict with the Technical Specifications, the Technical Specifications take precedence.
- ◊ - the use of these pre-approved products in some applications may require a Deign Exception.
- ◊ - When deemed to be in the best interest of the County, the County reserves the right to:
 - 1) remove a product from this list without notice, and 2) limit the number of pre-approved products or manufacturers

Hillsborough County Public Utilities Department Appendix B: Pre-approved Products and Materials

 Hillsborough County Florida		Optimal County Limit ☀	POTABLE WATER	RECLAIMED WATER	WASTEWATER (Gravity)	WASTEWATER (Force Main)	WASTEWATER (Pump Station)	Manufacturer	Part Name/ Model Number	Important Notes and Stipulations
			Yes	Yes	-	-	-			
Flow Meters Commercial or Industrial Service <i>PUD Requirement: ±2% Accuracy</i>	3"	No Limit	Yes	Yes	-	-	-	Badger Meter Inc	RecordAll-Turbo Series	
			Yes	Yes	-	-	-	Neptune Technology Group	HP Turbine	
			Yes	Yes	-	-	-	Sensus Metering Systems	Omini T ²	
			Yes	-	-	-	-	Master Meter	Octave Ultrasonic	
	4"	No Limit	Yes	Yes	-	-	-	Badger Meter Inc	RecordAll-Turbo Series	
			Yes	Yes	-	-	-	Neptune Technology Group	HP Turbine	
			Yes	Yes	-	-	-	Sensus Metering Systems	Omini T ²	
			Yes	-	-	-	-	Master Meter	Octave Ultrasonic	
	6"	No Limit	Yes	Yes	-	-	-	Badger Meter Inc	RecordAll-Turbo Series	
			Yes	Yes	-	-	-	Neptune Technology Group	HP Turbine	
			Yes	Yes	-	-	-	Sensus Metering Systems	Omini T ²	
			Yes	-	-	-	-	Master Meter	Octave Ultrasonic	
	8"	No Limit	Yes	Yes	-	-	-	Neptune Technology Group	HP Turbine	
			Yes	Yes	-	-	-	Sensus Metering Systems	Omini T ²	
			Yes	-	-	-	-	Master Meter	Octave Ultrasonic	
	10"	No Limit	Yes	Yes	-	-	-	Badger Meter Inc	RecordAll-Turbo Series	
			Yes	Yes	-	-	-	Neptune Technology Group	HP Turbine	
			Yes	-	-	-	-	Master Meter	Octave Ultrasonic	
			Yes	Yes	-	-	-	Sensus Metering Systems	Omini T ²	


- ◊ - PRC approval of a product will not be given, or considered, as part of an active bid or bid review.
- ◊ - Where this list may conflict with the Technical Specifications, the Technical Specifications take precedence.
- ◊ - the use of these pre-approved products in some applications may require a Deign Exception.
- ◊ - When deemed to be in the best interest of the County, the County reserves the right to:
 - 1) remove a product from this list without notice, and 2) limit the number of pre-approved products or manufacturers

Hillsborough County Public Utilities Department Appendix B: Pre-approved Products and Materials

		Optimal County Limit ☀	POTABLE WATER	RECLAIMED WATER	WASTEWATER (Gravity)	WASTEWATER (Force Main)	WASTEWATER (Pump Station)	Manufacturer	Part Name/ Model Number	Important Notes and Stipulations	
			Yes	Yes	-	-	-				
Flow Meters	Compound Service	1 1/2"	No Limit	Yes	Yes	-	-	-	Sensus Metering Systems	Omini C ²	FLxFL requires flange adapter to convert to FIPxFIP
			Yes	-	-	-	-	Master Meter	Octave Ultrasonic		
		2"	No Limit	Yes	Yes	-	-	-	Badger Meter Inc	RecordAll-Compound Series	Turbine x Disk (FL xFL)-->Requires flange adapter to convert to FIPxFIP
			Yes	Yes	-	-	-	Sensus Metering Systems	Omini C ²	(FL xFL)-->Requires flange adapter to convert to FIPxFIP	
			Yes	-	-	-	-	Master Meter	Octave Ultrasonic		
		3"	No Limit	Yes	Yes	-	-	-	Neptune Technology Group	Tru/Flo Compound	
			Yes	Yes	-	-	-	Sensus Metering Systems	Omini C ²		
			Yes	Yes	-	-	-	Badger Meter Inc	RecordAll-Compound Series		
			Yes	-	-	-	-	Master Meter	Octave Ultrasonic		
		4"	No Limit	Yes	Yes	-	-	-	Badger Meter Inc	RecordAll (Compound Series)	
			Yes	Yes	-	-	-	Neptune Technology Group	Tru/Flo Compound		
			Yes	Yes	-	-	-	Sensus Metering Systems	Omini C ²		
			Yes	-	-	-	-	Master Meter	Octave Ultrasonic		
		6"	No Limit	Yes	Yes	-	-	-	Neptune Technology Group	Tru/Flo Compound	
			Yes	Yes	-	-	-	Sensus Metering Systems	Omini C ²		
			Yes	Yes	-	-	-	Badger Meter Inc	RecordAll-Compound Series		
			Yes	-	-	-	-	Master Meter	Octave Ultrasonic		
		8"	No Limit	Yes	Yes	-	-	-	Sensus Metering Systems	Omini C ²	
			Yes	-	-	-	-	Master Meter	Octave Ultrasonic		
			-	-	-	-	-				
		10"	No Limit	Yes	Yes	-	-	-	Sensus Metering Systems	Omini C ²	
			Yes	-	-	-	-	Master Meter	Octave Ultrasonic		
			-	-	-	-	-				



◊ - PRC approval of a product will not be given, or considered, as part of an active bid or bid review.
 ◊ - Where this list may conflict with the Technical Specifications, the Technical Specifications take precedence.
 ◊ - the use of these pre-approved products in some applications may require a Deign Exception.
 ◊ - When deemed to be in the best interest of the County, the County reserves the right to:
 1) remove a product from this list without notice, and 2) limit the number of pre-approved products or manufacturers

Hillsborough County Public Utilities Department Appendix B: Pre-approved Products and Materials

 Hillsborough County Florida		Optimal County Limit ☀️	POTABLE WATER	RECLAIMED WATER	WASTEWATER (Gravity)	WASTEWATER (Force Main)	WASTEWATER (Pump Station)	Manufacturer	Part Name/ Model Number	Important Notes and Stipulations	
			Yes	-	-	-	-				
Flow Meters	Fire Service	3"	No Limit	Yes	-	-	-	-	Badger Meter Inc (Fire Series)	FSMA RecordAll	
				-	-	-	-	-			
		4"	No Limit	Yes	-	-	-	-	Master Meter	Octave Ultrasonic	
				Yes	-	-	-	-	Sensus Metering Systems	Omini F ²	
				Yes	-	-	-	-	Neptune Technology Group	HP Protectus III	
				Yes	-	-	-	-	Badger Meter Inc (Fire Series)	FSAA RecordAll	
	Yes			-	-	-	-	Badger Meter Inc (Fire Series)	FSMA RecordAll		
	6"	No Limit	Yes	-	-	-	-	Master Meter	Octave Ultrasonic		
			Yes	-	-	-	-	Sensus Metering Systems	Omini F ²		
			Yes	-	-	-	-	Neptune Technology Group	HP Protectus III		
			Yes	-	-	-	-	Badger Meter Inc (Fire Series)	FSAA RecordAll		
			Yes	-	-	-	-	Badger Meter Inc (Fire Series)	FSMA RecordAll		
			Yes	-	-	-	-	Badger Meter Inc (Fire Series)	FSAA-DB RecordAll	6" x 1.5" Disk Series	
	8"	No Limit	Yes	-	-	-	-	Master Meter	Octave Ultrasonic		
			Yes	-	-	-	-	Sensus Metering Systems	Omini F ²	Potable-->Must be NSF-61 stamped and approved.	
			Yes	-	-	-	-	Badger Meter Inc (Fire Series)	FSMA RecordAll		
			Yes	-	-	-	-	Badger Meter Inc (Fire Series)	FSAA RecordAll		
			Yes	-	-	-	-	Badger Meter Inc (Fire Series)	FSAA-DB RecordAll		
			Yes	-	-	-	-	Neptune Technology Group	HP Protectus III		
	10"	No Limit	Yes	-	-	-	-	Master Meter	Octave Ultrasonic		
			Yes	-	-	-	-	Sensus Metering Systems	Omini F ²		
			Yes	-	-	-	-	Neptune Technology Group	HP Protectus III		
			Yes	-	-	-	-	Badger Meter Inc (Fire Series)	FSMA RecordAll		
			Yes	-	-	-	-	Badger Meter Inc (Fire Series)	FSAA		


◊ - PRC approval of a product will not be given, or considered, as part of an active bid or bid review.
 ◊ - Where this list may conflict with the Technical Specifications, the Technical Specifications take precedence.
 ◊ - the use of these pre-approved products in some applications may require a Deign Exception.
 ◊ - When deemed to be in the best interest of the County, the County reserves the right to:
 1) remove a product from this list without notice, and 2) limit the number of pre-approved products or manufacturers

Hillsborough County Public Utilities Department Appendix B: Pre-approved Products and Materials

 Hillsborough County Florida		Optimal County Limit 	POTABLE WATER	RECLAIMED WATER	WASTEWATER (Gravity)	WASTEWATER (Force Main)	WASTEWATER (Pump Station)	Manufacturer	Part Name/ Model Number	Important Notes and Stipulations	
		Paints and Corrosion Systems	Interior Ceramic Epoxy Coatings (For Ductile Iron Pipes and Fittings) Required for all Sanitary sewer applications.	No Limit	-	-	Yes	Yes	Yes	Induron Protective Coatings	Protecto 401
-	-				Yes	Yes	Yes	Permite Corporation	Permax-CTF	Applied at 40 mils thick nominal by a certified applicator. See Permite Corporation website for special handling considerations.	
-	-				-	-	-				
Manhole Frame and Cover Protective Paint	No Limit		-	-	Yes	-	-	POR-15, INC	Prime: Prep & Ready Finish: POR-15		
			-	-	-	-	-				
			-	-	-	-	-				
Painting Materials for Aerial or Above Grade Piping, Fittings, and Valves (NACE Classified C5-I Environment) (VOC ≤ 2.8 lbs/gal, Est. Service Life ≥ 5yrs)	(Rust Inhibitive Field Primer) & (Exterior Finish)		No Limit	Yes	Yes	-	Yes	Yes	Tnemecc	(Primer) Typoxy Series 27WB (Finish) Endura Shield II 1074U (Ggloss)	
				Yes	Yes	-	Yes	Yes	Tnemecc	(Primer) Typoxy Series 27WB (Finish) Endura-Shield 1075U (Semi-Gloss)	
				Yes	Yes	-	Yes	Yes	Sherwin-Williams	(Primer) Dura Plate 235 Multi-Purpose Epoxy (Finish) Waterbased Acrolon 100 Urethane	
				Yes	Yes	-	Yes	Yes	Sherwin-Williams	(Primer) Macropoxy 646-100 (Finish) Waterbased Acrolon 100 Urethane	
				Yes	Yes	-	Yes	Yes	International Paint	(Primer) Intercure 200 HS (Finish) Interthane 990 HS	
				-	-	-	-	-			



◊ - PRC approval of a product will not be given, or considered, as part of an active bid or bid review.
 ◊ - Where this list may conflict with the Technical Specifications, the Technical Specifications take precedence.
 ◊ - the use of these pre-approved products in some applications may require a Deign Exception.
 ◊ - When deemed to be in the best interest of the County, the County reserves the right to:
 1) remove a product from this list without notice, and 2) limit the number of pre-approved products or manufacturers

Hillsborough County Public Utilities Department Appendix B: Pre-approved Products and Materials

 Hillsborough County Florida		Optimal County Limit ☀	POTABLE WATER	RECLAIMED WATER	WASTEWATER (Gravity)	WASTEWATER (Force Main)	WASTEWATER (Pump Station)	Manufacturer	Part Name/ Model Number	Important Notes and Stipulations
		No Limit	-	-	Yes	-	Yes	IET Systems	IET System 3: Prime: DS-101 (min 5 mils dft) Intermediate: DS-301 (min 125 mils dft) Finish: DS-401 (min 5 mils dft)	* Credentials must be checked for all coating applicators. * The applicator shall present current certification of training by the manufacturer in all aspects (technical and practical) of the corrosion protection system to the Engineer of Record (EOR) or the County Project Manager. * All documentation must indicate the name of the crew leader, with at least five (5) years of experience in the usage of the specific corrosion protection system. * When applicable for a project, training via manufacturer "shadowing" shall be mentioned in the documentation provided to the project manager or EOR."
New Applications	No Limit	-	-	Yes	-	Yes	CCI Spectrum Incorporated	SpectraShield (min 500 mils dft)		
Paints and Corrosion Systems Corrosion Protection Systems (County Approved Stamp must be applied on all Installations)	Rehabilitation Applications	No Limit	-	-	Yes	-	Yes	Raven Lining Systems	Primer: Raven 155 (min 8 mils dft) Finish: Raven 405 (min 125 mils dft)	
	No Limit	-	-	Yes	-	Yes	Sauereisen	Intermediate: 210T (min 125 mils dft) Finish: 210G (min 20 mils dft)		
	No Limit	-	-	Yes	-	Yes	Warren Environmental	Finish: 301-14 (min 100 mils dft)		
	No Limit	-	-	Yes	-	Yes	Industrial Maintenance Group (IMG)	SC 3900 FUB: (min: 100-200 dft)		
	No Limit	-	-	Yes	-	Yes	Sprayroq, LLC.	SprayWall: New construction minimum is 125 mils for corrosion barriers. For structural applications minimum thickness is 250 mils.		
	No Limit	-	-	-	-	Yes	Vortex Sevices-Applicator	Quadrex-GeoKrete - 0.5 inch to new		
	No Limit	-	-	Yes	-	Yes	CCI Spectrum Incorporated	SpectraShield (min 500 mils dft)		
	No Limit	-	-	Yes	-	Yes	IET Systems	IET System 3: Prime: DS-101 (min 5 mils dft) Intermediate: DS-301 (min 125 mils dft) Finish: DS-401 (min 5 mils dft)		
	No Limit	-	-	Yes	-	Yes	Raven Lining Systems	Underlay: Raven 705CA (min 8 mils dft) Primer: Raven 155 (min 8 mils dft) Finish: Raven 405 (min 125 mils dft)		
	No Limit	-	-	Yes	-	Yes	Sauereisen	Underlay: F-121 Intermediate: 210T (min 125 mils dft) Finish: 210G (min 20 mils dft)		
No Limit	-	-	Yes	-	Yes	Warren Environmental	Intermediate: 301-18 (min 500 mils dft) Finish: 301-14 (min 100 mils dft)			
No Limit	-	-	Yes	-	Yes	Industrial Maintenance Group (IMG)	Underlay: 40 mils cementitious (typ) Finish: SC 3900 FUB (120 mils)			
No Limit	-	-	Yes	-	Yes	Sprayroq, LLC.	SprayWall: Existing construction minimum is 125 mils for corrosion barriers. For structural applications minimum thickness is 250 mils.			
No Limit	-	-	Yes	-	Yes	Vortex Services Applicator	Quadrex-GeoKrete - 1-inch thickness to structural Restoration			


◊ - PRC approval of a product will not be given, or considered, as part of an active bid or bid review.
 ◊ - Where this list may conflict with the Technical Specifications, the Technical Specifications take precedence.
 ◊ - the use of these pre-approved products in some applications may require a Deign Exception.
 ◊ - When deemed to be in the best interest of the County, the County reserves the right to:
 1) remove a product from this list without notice, and 2) limit the number of pre-approved products or manufacturers

Hillsborough County Public Utilities Department Appendix B: Pre-approved Products and Materials

 Hillsborough County Florida			 Optimal County Limit	POTABLE WATER	RECLAIMED WATER	WASTEWATER (Gravity)	WASTEWATER (Force Main)	WASTEWATER (Pump Station)	Manufacturer	Part Name/ Model Number	Important Notes and Stipulations
				Yes	Yes	-	Yes	Yes			
Pipe & Pumps	Ductile Iron Pipe <i>(Ceramic Epoxy Coating is required for Sanitary Sewer Applications)</i>	Push-On, Flanged, and Mech Joint (4" & up)	No Limit	Yes	Yes	-	Yes	Yes	U.S. Pipe Company		Push-On gasket Tyton.
				Yes	Yes	-	Yes	Yes	American Ductile Iron Pipe Company		Push-On gasket Fastite.
				Yes	Yes	-	Yes	Yes	McWane Inc. - Ductile Iron Pipe Group		Push-On gasket Tyton / Fastite.
				-	-	-	-	-			
	With Mfg Restrained Joint	No Limit	Yes	Yes	-	Yes	-	U.S. Pipe Company	TR Flex Joint		
			Yes	Yes	-	Yes	-	McWane Inc. - Ductile Iron Pipe Group	TR Flex Joint		
			Yes	Yes	-	Yes	-	American Ductile Iron Pipe Company	Flex Ring	4" to 42"	
			-	-	-	-	-				



♦ - PRC approval of a product will not be given, or considered, as part of an active bid or bid review.
 ♦ - Where this list may conflict with the Technical Specifications, the Technical Specifications take precedence.
 ♦ - the use of these pre-approved products in some applications may require a Deign Exception.
 ♦ - When deemed to be in the best interest of the County, the County reserves the right to:
 1) remove a product from this list without notice, and 2) limit the number of pre-approved products or manufacturers

Hillsborough County Public Utilities Department Appendix B: Pre-approved Products and Materials

 Hillsborough County Florida		Optimal County Limit ☀	POTABLE WATER	RECLAIMED WATER	WASTEWATER (Gravity)	WASTEWATER (Force Main)	WASTEWATER (Pump Station)	Manufacturer	Part Name/ Model Number	Important Notes and Stipulations	
Pipe & Pumps	PVC Pipe <i>(Approved DR in Technical Specifications)</i>	2" or 3" (AWWA 2241)	No Limit	-	Yes	-	-	-	Diamond Plastics Corporation		
				-	Yes	-	-	-	National Pipe & Plastics Inc		
				-	Yes	-	-	-	North American Pipe		
				-	-	-	-	-			
		4" to 12" (AWWA C900 & C909)	No Limit	Yes	Yes	Yes	Yes	-	Diamond Plastics Corporation	AWWA C900	
				Yes	Yes	Yes	Yes	-	JM Eagle	AWWA C900 & C909	
				Yes	Yes	Yes	Yes	-	National Pipe & Plastics Inc	AWWA C900	
				Yes	Yes	Yes	Yes	-	North American Pipe	AWWA C900	
				-	-	-	-	-			
		4" to 12" (ASTM D 3034)	No Limit	-	-	Yes	-	-	Diamond Plastics Corporation		
				-	-	Yes	-	-	JM Eagle	Gravity Sewer Pipe	
				-	-	Yes	-	-	National Pipe & Plastics Inc	Plastic Sewer Main (PSM) Pipe	
				-	-	Yes	-	-	North American Pipe		
				-	-	-	-	-			
		14" and Above AWWA C905 <i>(Public Utilities Department Design Exception Required)</i>	No limit	Yes	Yes	Yes	Yes	-	JM Eagle	Big Blue	Specify appropriate pipe color for service.
				Yes	Yes	Yes	Yes	-	Diamond Plastics Corporation	Trans 21	Specify appropriate pipe color for service.
				Yes	Yes	Yes	Yes	-	North American Pipe		Specify appropriate pipe color for service.
				-	-	-	-	-			
		With Mfg Restrained Joint	No Limit	Yes	Yes	-	Yes	-	North American Speciality Products	Certa-Lok C900 RJ	4"-12"
				Yes	Yes	-	Yes	-	North American Speciality Products	Certa-Lok C900 RJIB	4"-12"
Yes	Yes			-	Yes	-	Underground Solutions	Fusible C-900®, Fusible C-905®, Fusible PVC™ (FPVC™)	Approved 4"-30".		
Yes	Yes			-	Yes	-	Underground Solutions	TerraBrute CR C-900	4" to 12", *Requires Design Exception to collect information.		





- ◊ - PRC approval of a product will not be given, or considered, as part of an active bid or bid review.
- ◊ - Where this list may conflict with the Technical Specifications, the Technical Specifications take precedence.
- ◊ - the use of these pre-approved products in some applications may require a Design Exception.
- ◊ - When deemed to be in the best interest of the County, the County reserves the right to:
 - 1) remove a product from this list without notice, and 2) limit the number of pre-approved products or manufacturers

Hillsborough County Public Utilities Department Appendix B: Pre-approved Products and Materials

 Hillsborough County Florida			 Optimal County Limit	POTABLE WATER	RECLAIMED WATER	WASTEWATER (Gravity)	WASTEWATER (Force Main)	WASTEWATER (Pump Station)	Manufacturer	Part Name/ Model Number	Important Notes and Stipulations	
				Yes	-	-	-	-				
Pipe & Pumps	Polyethylene Pipe, 1" & 2" (AWWA C901)	No Limit	Yes	-	-	-	-	Performance Pipe <i>(A Chevron Phillips Chemical Company)</i>	DriscoPlex 5100 Ultra-Line	Black tube. Must have BLUE stripe for Potable Applications. PE4710 SDR 9		
			-	Yes	-	-	-	Performance Pipe <i>(A Chevron Phillips Chemical Company)</i>	DriscoPlex 5100 Ultra-Line	Black tube. Must have LAVENDER stripe for Reclaimed Applications. PE4710 SDR 9		
			Yes	-	-	-	-	Endot	Endopure	PE 4710 SDR 9		
			-	Yes	-	-	-	Endot	Endocore RWT	PE 4710 SDR 9		
			Yes	-	-	-	-	Charter Plastics	Blue Ice CTS Tubing	PE 4710 SDR 9		
			-	Yes	-	-	-	Charter Plastics	Lavender Ice CTS Tubing	PE 4710 SDR 9		
			Yes	-	-	-	-	ADS	Polyflex CTS Tubing (Blue)	PE 4710 SDR 9		
			-	Yes	-	-	-	ADS	Polyflex CTS Tubing (Lavender)	PE 4710 SDR 9		
			-	-	-	-	-					
	Centrifugal Overhung Impeller Type Submersible Pumps	Low-Pressure (Light Duty) Applications	Grinder	2	-	-	-	-	Yes	Sulzer	ABS Piranha 09 /2D	
					-	-	-	-	-			
		Pressurized Applications	NonClog	2	-	-	-	-	-	Xylem	Flygt	>60 gpm peak design flow
					-	-	-	-	-	Pentair	Hydromatic	>60 gpm peak design flow, S4T requires ≥ 8-ft wetwell and oversized hatch. Rejected Models: H4Q, S4P
			Chopper/Cutter	2	-	-	-	-	-	Xylem	Flygt	
					-	-	-	-	-	Pentair	Hydromatic	
Grinder	2	-	-	-	-	Yes	Xylem	Flygt	< 80 gpm peak design flow			
		-	-	-	-	-						






- ◊ - PRC approval of a product will not be given, or considered, as part of an active bid or bid review.
- ◊ - Where this list may conflict with the Technical Specifications, the Technical Specifications take precedence.
- ◊ - the use of these pre-approved products in some applications may require a Deign Exception.
- ◊ - When deemed to be in the best interest of the County, the County reserves the right to:
 - 1) remove a product from this list without notice, and 2) limit the number of pre-approved products or manufacturers

Hillsborough County Public Utilities Department Appendix B: Pre-approved Products and Materials

 Hillsborough County Florida			 Optimal County Limit	POTABLE WATER	RECLAIMED WATER	WASTEWATER (Gravity)	WASTEWATER (Force Main)	WASTEWATER (Pump Station)	Manufacturer	Part Name/ Model Number	Important Notes and Stipulations
				Yes	Yes	-	Yes	-			
Pipe Restraints	PVC - DIP	MJ - Ring (Serration Style) 	No Limit	Yes	Yes	-	Yes	-	Ford Meter Box Company Inc.	Uni-flange 1300	2" to 36"
				Yes	Yes	-	Yes	-	Sigma	PV-Lok PWM	2" to 48"
				Yes	Yes	-	Yes	-	JCM Industries	610	4" to 12"
									Star Pipe Products	1000G2	4" to 12"
				-	-	-	-	-			
	PVC - DIP	MJ - Gland (Wedge Action) 	No Limit	Yes	Yes	-	Yes	-	EBAA Iron Company	2000 PV	4" to 36"
				Yes	Yes	-	Yes	-	Sigma	One-Lock SLCE	
				Yes	Yes	-	Yes	-	Ford Meter Box Company Inc.	Uni-Flange 1500	
				Yes	Yes	-	Yes	-	Star Pipe Products	4000G2	3" to 12"
				Yes	Yes	-	Yes	-	Romac Industries	GripRing	
				Yes	Yes	-	Yes	-	Tyler/Union	Tuf Grip TLP	
				Yes	Yes	-	Yes	-	Serampore Industries Private Ltd. (SIP)	EZPVCU Ultra	4" to 12"



◊ - PRC approval of a product will not be given, or considered, as part of an active bid or bid review.
 ◊ - Where this list may conflict with the Technical Specifications, the Technical Specifications take precedence.
 ◊ - the use of these pre-approved products in some applications may require a Design Exception.
 ◊ - When deemed to be in the best interest of the County, the County reserves the right to:
 1) remove a product from this list without notice, and 2) limit the number of pre-approved products or manufacturers

Hillsborough County Public Utilities Department Appendix B: Pre-approved Products and Materials

 Hillsborough County Florida		Optimal County Limit ☀	POTABLE WATER	RECLAIMED WATER	WASTEWATER (Gravity)	WASTEWATER (Force Main)	WASTEWATER (Pump Station)	Manufacturer	Part Name/ Model Number	Important Notes and Stipulations	
			Yes	Yes	-	Yes	-				
Pipe Restraints	DIP - DIP	Ring - Ring 	No Limit	Yes	Yes	-	Yes	-	EBAA Iron Company	1600TD	4" to 12"
			No Limit	Yes	Yes	-	Yes	-	Ford Meter Box Company Inc.	Uni-flange 1390	4" to 12"
			No Limit	Yes	Yes	-	Yes	-	Star Pipe Products	1100G2	4" to 12"
			No Limit	Yes	Yes	-	Yes	-	Star Pipe Products	3100P	4" to 12"
			No Limit	Yes	Yes	-	Yes	-	Sigma	PV-Lok PWP	
			No Limit	Yes	Yes	-	Yes	-	Sigma	One-Lok SLDEH	
		MJ - Ring (Serration Style) 	No Limit	Yes	Yes	-	Yes	-	Star Pipe Products	1000G2	4" to 12"
			No Limit	Yes	Yes	-	Yes	-	JCM Industries	610	4" to 12"
			No Limit	Yes	Yes	-	Yes	-	EBAA Iron Company	MegaLug 1100	
		MJ - Gland (Wedge Action) 	No Limit	Yes	Yes	-	Yes	-	Ford Meter Box Company Inc.	Uniflange 1400	
			No Limit	Yes	Yes	-	Yes	-	Sigma	One-Lok D-SLDE	
			No Limit	Yes	Yes	-	Yes	-	Sigma	One-Lok SLDE	
	No Limit		Yes	Yes	-	Yes	-	Romac Industries	GripRing		
	No Limit		Yes	Yes	-	Yes	-	Star Pipe Products	StarGrip 3000	4" to 12"	
	No Limit		Yes	Yes	-	Yes	-	Tyler/Union	Tuf Grip TLD		
No Limit	Yes		Yes	-	Yes	-	Serampore Industries Private Ltd. (SIP)	EZD-Grip	3" to 24"		
No Limit	Yes		Yes	-	Yes	-	Ford Meter Box Company Inc.	Uniflange 1350	4" to 12"		
PVC - PVC	Ring - Ring 	No Limit	Yes	Yes	-	Yes	-	Ford Meter Box Company Inc.	Uniflange 1390	4" to 12"	
		No Limit	Yes	Yes	-	Yes	-	EBAA Iron Company	1600 (& 1600TD)	4" to 12"	
		No Limit	Yes	Yes	-	Yes	-	JCM Industries	JCM 620	4" to 12"	
		No Limit	Yes	Yes	-	Yes	-	Sigma	PV-Lok PWP	2" to 12"	
		No Limit	Yes	Yes	-	Yes	-	Star Pipe Products	1100G2	4" to 12"	
		No Limit	Yes	Yes	-	Yes	-	Star Pipe Products	4100P	4" to 12"	
		No Limit	-	-	-	-	-	Serampore Industries Private Ltd. (SIP)	EZ-Grip PTP Series	4" to 12"	


◊ - PRC approval of a product will not be given, or considered, as part of an active bid or bid review.
 ◊ - Where this list may conflict with the Technical Specifications, the Technical Specifications take precedence.
 ◊ - the use of these pre-approved products in some applications may require a Design Exception.
 ◊ - When deemed to be in the best interest of the County, the County reserves the right to:
 1) remove a product from this list without notice, and 2) limit the number of pre-approved products or manufacturers

Hillsborough County Public Utilities Department Appendix B: Pre-approved Products and Materials

 Hillsborough County Florida			 Optimal County Limit	POTABLE WATER	RECLAIMED WATER	WASTEWATER (Gravity)	WASTEWATER (Force Main)	WASTEWATER (Pump Station)	Manufacturer	Part Name/ Model Number	Important Notes and Stipulations
				Yes	Yes	-	Yes	-			
Pipe Restraints	Miscellaneous	DIP-DIP	No Limit	Yes	Yes	-	Yes	-	U.S. Pipe Company	TR Flex Gripper Ring	4" to 36" (For use with TR Flex Joint DI Pipe)
				Yes	Yes	-	Yes	-	McWane Inc.	TR Flex Gripper Ring	4" to 36" (For use with TR Flex Joint DI Pipe)
				Yes	Yes	-	Yes	-	U.S. Pipe Company	Field Lok 350 Gasket	4" to 12" (Requires Prior PUD Approval) Not for directional drill or above grade use. Review assembly instructions before use.
				Yes	Yes	-	Yes	-	American Ductile Iron Pipe Company	Fast-Grip Gasket	4" to 12" (Requires Prior PUD Approval) Not for directional drill or above grade use. Review assembly instructions before use.
				Yes	Yes	-	Yes	-	McWane Inc.	Sure Stop 350 Gasket	4" to 12" (Requires Prior PUD Approval) Not for directional drill or above grade use. Review assembly instructions before use.
	PVC-PVC		No Limit								
				Yes	Yes	-	Yes	-	Ransom International LLC. Subsidiary of McWane Inc.	RieberLoc- For C900 PVC DR 18 a& 14	4" to 12" (Requires Prior PUD Approval) Not for directional drill or above grade use. Review assembly instructions before use.


◊ - PRC approval of a product will not be given, or considered, as part of an active bid or bid review.
 ◊ - Where this list may conflict with the Technical Specifications, the Technical Specifications take precedence.
 ◊ - the use of these pre-approved products in some applications may require a Design Exception.
 ◊ - When deemed to be in the best interest of the County, the County reserves the right to:
 1) remove a product from this list without notice, and 2) limit the number of pre-approved products or manufacturers

Hillsborough County Public Utilities Department Appendix B: Pre-approved Products and Materials

 Hillsborough County Florida				Optimal County Limit ☀	POTABLE WATER	RECLAIMED WATER	WASTEWATER (Gravity)	WASTEWATER (Force Main)	WASTEWATER (Pump Station)	Manufacturer	Part Name/ Model Number	Important Notes and Stipulations
				No Limit	-	-	-	Yes	-			
Surface and Vent Boxes	Vent Box for Wastewater Force Main Air Release Valve	Combo (Box & Lid)	No Limit	-	-	-	Yes	-	DFW Plastics, Inc	DFW37C-12-AF1-SARV-HILLS	Black with lid lettering "Hillsborough County Sewer ARV"	
			No Limit	-	-	-	-	-				
		Lids	No Limit	-	-	-	Yes	-	DFW Plastics, Inc	DFW37C-AF1-SARV-LID-HILLS	Black with lettering "Hillsborough County Sewer ARV"	
			No Limit	-	-	-	-	-				
		Base Boxes	No Limit	-	-	-	Yes	-	DFW Plastics, Inc	DFW37C-12-BODY	Wastewater-->Black	
			No Limit	-	-	-	-	-				
	Water Meter Boxes	Single Service	Combo (Base & Lid)	No Limit	Yes	-	-	-	-	DFW Plastics, Inc	DFW37C-12-AF1HILLS	Potable-->Black
				No Limit	-	Yes	-	-	-	DFW Plastics, Inc	DFW37C5-12-AF5 HILLS	Reclaimed-->Pantone 522C
			No Limit	-	-	-	-	-				
		Lids	No Limit	Yes	-	-	-	-	DFW Plastics, Inc	DFW37C-AF1HILLS	Potable-->Black	
			No Limit	-	Yes	-	-	-	DFW Plastics, Inc	DFW37C-AF5-HILLS	Reclaimed-->Pantone 522C	
		Base Boxes	No Limit	-	-	-	-	-				
No Limit	Yes		-	-	-	-	DFW Plastics, Inc	DFW37C-12-BODY	Potable-->Black			
		No Limit	-	Yes	-	-	DFW Plastics, Inc	DFW37C5-12-BODY	Reclaimed-->Pantone 522C			



- ◊ - PRC approval of a product will not be given, or considered, as part of an active bid or bid review.
- ◊ - Where this list may conflict with the Technical Specifications, the Technical Specifications take precedence.
- ◊ - the use of these pre-approved products in some applications may require a Deign Exception.
- ◊ - When deemed to be in the best interest of the County, the County reserves the right to:
 - 1) remove a product from this list without notice, and 2) limit the number of pre-approved products or manufacturers

Hillsborough County Public Utilities Department Appendix B: Pre-approved Products and Materials

 Hillsborough County Florida		Optimal County Limit ☀					Manufacturer	Part Name/ Model Number	Important Notes and Stipulations			
		POTABLE WATER	RECLAIMED WATER	WASTEWATER (Gravity)	WASTEWATER (Force Main)	WASTEWATER (Pump Station)						
Surface and Vent Boxes	Water Meter Boxes	Dual Service	Combo (Box & Lid)	No Limit	Yes	-	-	-	-	DFW Plastics, Inc	DFW39C-12-AF1-HILLS	Potable-->Black
				No Limit	-	Yes	-	-	-	DFW Plastics, Inc	DFW39C5-12-AF5-HILLS	Reclaimed-->Pantone 522C
			Lids	No Limit	Yes	-	-	-	-	DFW Plastics, Inc	DFW39C-AF1-LID-HILLS	Potable-->Black
				No Limit	-	Yes	-	-	-	DFW Plastics, Inc	DFW39C-AF5-LID-HILLS	Reclaimed-->Pantone 522C
			Base Boxes	No Limit	-	-	-	-	-			
				No Limit	Yes	-	-	-	-	DFW Plastics, Inc	DFW39C-12-BODY-HILLS	Potable-->Black
		Commercial Use	Combo (Box & Lid)	No Limit	Yes	-	-	-	-	DFW Plastics, Inc	DFW1730-12-AF1-HILLS	Potable-->Black
				No Limit	-	Yes	-	-	-	DFW Plastics, Inc	DFW1730-12-AF5-HILLS	Reclaimed --> Pantone 522C
			Lids	No Limit	Yes	-	-	-	-	DFW Plastics, Inc	DFW1730-AF1-LID-HILLS	Potable-->Black
				No Limit	-	Yes	-	-	-	DFW Plastics, Inc	DFW1730-AF5-LID-HILLS	Reclaimed --> Pantone 522C
			Base Boxes	No Limit	Yes	Yes	-	-	-	DFW Plastics, Inc	DFW1730-12-BODY-HILLS	Potable-->Black
				No Limit	-	Yes	-	-	-	DFW Plastics, Inc	DFW1730C5-12-BODY-HILLS	Reclaimed --> Pantone 522C


- ◊ - PRC approval of a product will not be given, or considered, as part of an active bid or bid review.
- ◊ - Where this list may conflict with the Technical Specifications, the Technical Specifications take precedence.
- ◊ - the use of these pre-approved products in some applications may require a Deign Exception.
- ◊ - When deemed to be in the best interest of the County, the County reserves the right to:
 - 1) remove a product from this list without notice, and 2) limit the number of pre-approved products or manufacturers

**Hillsborough County Public Utilities Department
Appendix B: Pre-approved Products and Materials**

 Hillsborough County Florida			Optimal County Limit ☀	POTABLE WATER	RECLAIMED WATER	WASTEWATER (Gravity)	WASTEWATER (Force Main)	WASTEWATER (Pump Station)	Manufacturer	Part Name/ Model Number	Important Notes and Stipulations	
Valves	Air-Release and Combination Air Valves			No Limit	Yes	Yes	-	-	-	Crispin Multiplex Manufacturing	PL 20	Air-Release Valve.
					Yes	Yes	-	-	-	Valmatic	45	Air-Release Valve.
					Yes	-	-	-	-	A.R.I. Flow Control	D-040PT02	Combination Air Valve for Potable Water
					-	Yes	-	-	-	A.R.I. Flow Control	D-021PT02	Combination Air Valve for Reclaimed Water
					-	-	-	-	-	A.R.I. Flow Control	D-025TPV02	Combination Air Valve. Vacuum check valve required (D-025TPV02) unless a major vacuum condition exists and is specified by the design engineer via a design exception (D-025PT02 is same without one-way valve in high vacumme applications). Reinforced Nylon body, SST Hardware and trim.
					-	Yes	-	Yes	-	H-Tec	Model 986	
					-	-	-	-	-			
	Ball Valves Ball stem and Body shall be 316 Stainless Steel, non-lubricated free-floating ball type, full port. Handle, nuts and washers shall be 300 series Stainless Steel 			No Limit	-	-	-	-	Yes	Jamesbury Corporation (Metso Automation)	Eliminator Series	Full Port Female IP (NPT) Inlet and Outlet Pump Stations: For discharge piping gauge port isolation Approved up to 1/2".
					-	-	-	Yes	Yes	FNW	Figure 220	Full port Female IP (NPT) Inlet and Outlet Pump stations: For discharge piping gauge port isolation Force mains: For ARV isolation and/or pressure release Typically 1" and 2"
					-	-	-	-	Yes	Jamesbury Corporation (Metso Automation)	Full Bore Series 9000	Full port, ANSI Class 150 Flanged Grinder Pump Stations: For discharge piping isolation Typically 2"
					-	-	-	-	-			
	Check Valves 2" & larger Metal & Resilient Hinge Arm Flapper Disk			No Limit	Yes	Yes	-	-	Yes	Kennedy Valve Company (McWane)/ M&H (McWane)	Style 1106LW (lever & weight)	2" to 12". Bronze to bronze seat.
					Yes	Yes	-	-	Yes	Kennedy Valve Company (McWane)/ M&H (McWane)	Style 106AW/ 159-02 (lever & weight)	14" and up. Resilient to bronze seat.
					Yes	Yes	-	-	Yes	American Flow Control	50-SC Series	8" to 14"
				No Limit	-	-	-	-	Yes	Val-Matic	Series 500A	XX represents size Must have stainless steel cover bolts, disc position indicator, and backflow actuator. Resilient hinge arm style.
-					-	-	-	Yes				
-					-	-	-	Yes	GA Industries (North American Valve and Gate Group)	RF200-D	Must have stainless steel cover bolts, disc position indicator, and backflow actuator.	
-					-	-	-	Yes				



◊ - PRC approval of a product will not be given, or considered, as part of an active bid or bid review.
 ◊ - Where this list may conflict with the Technical Specifications, the Technical Specifications take precedence.
 ◊ - the use of these pre-approved products in some applications may require a Design Exception.
 ◊ - When deemed to be in the best interest of the County, the County reserves the right to:
 1) remove a product from this list without notice, and 2) limit the number of pre-approved products or manufacturers

Hillsborough County Public Utilities Department Appendix B: Pre-approved Products and Materials

		Optimal County Limit ☀	POTABLE WATER	RECLAIMED WATER	WASTEWATER (Gravity)	WASTEWATER (Force Main)	WASTEWATER (Pump Station)	Manufacturer	Part Name/ Model Number	Important Notes and Stipulations	
Valves	Gate Valves (Resilient Seated C509 & C515)	2" to 3"	No Limit	Yes	Yes	-	-	Yes	U.S. Pipe Company	A-USP0-6	Cast Iron, NRS, Flanged
				Yes	Yes	-	-	-	U.S. Pipe Company	R-USP0-6	Cast Iron, OS&Y, Flanged
				Yes	Yes	-	-	Yes	U.S. Pipe Company	A-USP0-8	Cast Iron, NRS, NPT
				Yes	Yes	-	-	Yes	Mueller Co.	A-2361 Series	DI, NRS, NPT, Flanged or OS&Y, T304 SST hardware, EPDMdisc/gaskets, (No OS&Y at pump station)
				Yes	Yes	-	-	-	U.S. Pipe Company	R-USP0-8	Cast Iron, OS&Y, NPT
				Yes	Yes	-	-	Yes	Clow Valve Co. (McWane)	Model 2638, 2639 & 2640	Ductile or Cast Iron, NRS or OS&Y (No OS&Y at Pump Station)
				Yes	Yes	-	-	Yes	American Flow Control	2500 Series	Ductile Iron, NRS or OS&Y (No OS&Y at Pump Station)
				-	-	-	-	-			
				Yes	Yes	-	-	-	U.S. Pipe Company	USP0 Series	Cast Iron, NRS or OS&Y
		Yes	Yes	-	-	Yes	Mueller Co.	A-2361 Series	DI, NRS, Flanged or OS&Y, T304 SST hardware, EPDMdisc/gaskets, (Aquagrip x Aquagrip - Must have Restraint Bolts), (No OS&Y at pump station)		
		-	-	-	-	-					
		Yes	Yes	-	-	Yes	U.S. Pipe Company	A-USP0-6	Cast Iron, NRS, Flanged		
		Yes	Yes	-	-	Yes	American Flow Control	2500 Series	Ductile Iron, NRS or OS&Y (No OS&Y at Pump Station)		
		Yes	Yes	-	-	Yes	Kennedy Valve Company (McWane)		Ductile or Cast Iron, NRS or OS&Y (No OS&Y at pump station)		
		Yes	Yes	-	-	Yes	Clow Valve Co. (McWane)	Model 2638	Ductile or Cast Iron, NRS or OS&Y (No OS&Y at Pump Station)		
	Yes	Yes	-	-	Yes	Clow Valve Co. (McWane)	Model 2639	Ductile or Cast Iron, NRS or OS&Y (No OS&Y at Pump Station)			
	Yes	Yes	-	-	Yes	Clow Valve Co. (McWane)	Model 2640	Ductile or Cast Iron, NRS or OS&Y (No OS&Y at Pump Station)			
	Yes	Yes	-	-	-	M&H Valve Co. (McWane)	4068	Cast Iron, OS&Y, Flanged			
	Yes	Yes	-	-	Yes	M&H Valve Co. (McWane)	4067	Cast Iron, NRS			
	Yes	Yes	-	-	Yes	American Flow Control	2500 Series	Ductile Iron, NRS or OS&Y (No OS&Y at Pump Station)			
	Yes	Yes	-	-	Yes	Clow Valve Co. (McWane)	Model 2638	Ductile Iron, NRS or OS&Y (No OS&Y at Pump Station).			
	Yes	Yes	-	-	Yes	Mueller Co.	2361 Series	DI, NRS or OS&Y, T304 SST hardware, EPDM disc/gaskets, (No OS&Y at pump station)			
	Yes	Yes	-	-	-	U.S. Pipe Company	USP1 Series	DI, NRS or OS&Y, T304 SST hardware, EPDM disc/gaskets * Larger than 36" is not NSF 61 Certified			
	-	-	-	-	Yes	U.S. Pipe Company	A-USP1-6	DI, NRS, Flanged, T304 SST hardware, EPDM disc/gaskets			
	-	-	-	-	-						


◊ - PRC approval of a product will not be given, or considered, as part of an active bid or bid review.
 ◊ - Where this list may conflict with the Technical Specifications, the Technical Specifications take precedence.
 ◊ - the use of these pre-approved products in some applications may require a Design Exception.
 ◊ - When deemed to be in the best interest of the County, the County reserves the right to:
 1) remove a product from this list without notice, and 2) limit the number of pre-approved products or manufacturers

Hillsborough County Public Utilities Department Appendix B: Pre-approved Products and Materials

		Optimal County Limit ☀	POTABLE WATER	RECLAIMED WATER	WASTEWATER (Gravity)	WASTEWATER (Force Main)	WASTEWATER (Pump Station)	Manufacturer	Part Name/ Model Number	Important Notes and Stipulations	
			POTABLE WATER	RECLAIMED WATER	WASTEWATER (Gravity)	WASTEWATER (Force Main)	WASTEWATER (Pump Station)				
Valves	Corporation Stops 	No Limit	Yes	-	-	-	-	Ford Meter Box Company INC	FB 1700-7-NL	Ball--[Male AWWA IP Thread Inlet] x [Threaded Female IP Outlet]	
			Yes	-	-	-	-	Mueller Co.	B20046N	Ball--[Male AWWA IP Thread Inlet] x [Threaded Female IP Outlet]	
			Yes	Yes	-	-	-				
			Yes	Yes	-	-	-	Ford Meter Box Company INC	FB-1100-X NL (Entire Line)	Ball--[Male AWWA IP Thread Inlet] x [CTS Tubing Outlet]	
			Yes	Yes	-	-	-				
			Yes	Yes	-	-	-	Mueller Co.	P25028N	Ball--[Male AWWA IP Thread Inlet] x [CTS Tubing Outlet]	
			Yes	Yes	-	-	-				
			Yes	Yes	-	-	-	A.Y. McDonald	73149B	Ball - MNPT x FNPT	
			Yes	Yes	-	-	-	A.Y. McDonald	74704B-22	Ball - MNPT x CTS Compression	
	Curb Stops	No Limit	Yes	Yes	-	-	-	Ford Meter Box Company INC	B41-XXXW-NL(Entire Line)	Ball--[CTS Tubing Inlet] x [Threaded Female IP Outlet]	
			Yes	Yes	-	-	-	A.Y. McDonald	76102W-22	Ball - CTS compression x FNPT	
			-	-	-	-	-				
	Meter Valves	Single Service	No Limit	Yes	-	-	-	-	Ford Meter Box Company INC	B43-XXXW-NL (Entire Line)	Ball--[CTS Tubing Inlet] x [Meter Swivel Nut Outlet]
				-	Yes	-	-	-	Ford Meter Box Company INC	BRW 43-XXXW-NL (Entire Line)	Ball--[CTS Tubing Inlet] x [Meter Swivel Nut Outlet]
				Yes	Yes	-	-	-	Mueller Co.	P24350N	Ball--[CTS Tubing Inlet] x [Meter Swivel Nut Outlet]
				Yes	Yes	-	-	-	A.Y. McDonald	76100MW-22	Ball - CTS compression x meter
				-	Yes	-	-	-	A.Y. McDonald	76100MW-22RWC	Ball - CTS compression x meter
				-	-	-	-	-			
		Angle Service	No Limit	Yes	Yes	-	-	-	Ford Meter Box Company INC	BA43-342W-NL	Ball--[CTS Tubing Inlet] x [Meter Swivel Nut Outlet]
				Yes	Yes	-	-	-	A.Y. McDonald	74602B-22	Ball - CTS compression x meter
		Branched or Dual Service	No Limit	Yes	-	-	-	-	Ford Meter Box Company INC	Assembly: UVB43-42W-NL	2 Ball Angle Valve [Female IP Inlet] X [Meter Swivel Nut Outlet] Branch Pipes [CTS Tubing Inlet] x [2 Male AWWA IP Outlets]
				-	-	-	-	-	Ford Meter Box Company INC	Assembly: UVBS43-42W-NL	2 Straight Ball Valve [Female IP Inlet] X [Meter Swivel Nut Outlet] Branch Pipes [CTS Tubing Inlet] x [2 Male AWWA IP Outlets]
				-	Yes	-	-	-	Ford Meter Box Company INC	Assembly: UVBRW43-42W	2 Ball Angle Valve [Female IP Inlet] X [Meter Swivel Nut Outlet] Branch Pipes [CTS Tubing Inlet] x [2 Male AWWA IP Outlets]
				Yes	Yes	-	-	-	Mueller Co.	Must be ordered as Assembly Two B24265N One P15363N	(Installed Only as Assembly) 2 Ball Angle Valves [Female IP Inlet] X [Meter Swivel Nut Outlet] Branch Pipes [CTS Tubing Inlet] x [2 Male AWWA IP Outlets]
Yes	Yes			-	-	-	A.Y. McDonald	709U2BW-22	CTS compression x meter swivel nut with saddle		
-	-			-	-	-					


◊ - PRC approval of a product will not be given, or considered, as part of an active bid or bid review.
 ◊ - Where this list may conflict with the Technical Specifications, the Technical Specifications take precedence.
 ◊ - the use of these pre-approved products in some applications may require a Design Exception.
 ◊ - When deemed to be in the best interest of the County, the County reserves the right to:
 1) remove a product from this list without notice, and 2) limit the number of pre-approved products or manufacturers

**Hillsborough County Public Utilities Department
Appendix B: Pre-approved Products and Materials**

		Optimal County Limit ☀	POTABLE WATER	RECLAIMED WATER	WASTEWATER (Gravity)	WASTEWATER (Force Main)	WASTEWATER (Pump Station)	Manufacturer	Part Name/ Model Number	Important Notes and Stipulations
		No Limit	-	-	-	Yes	-			
Valves	Plug Valves Must have internal and external epoxy coating 10 mils minimum. Valves and gearing shall be rated for a minimum of 150 psi and shall provide drip-tight shut off with this pressure in either direction. 3"-12" round port, 14"-36" rectangular port area must equal 100% of pipe area, 304 stainless steel external hardware required. For wastewater, seat-end must face into the direction of predominant flow. Inspectors may request packing slip to verify specifications on the job site.		-	-	-	Yes	-	GA Industries	Plug Valves	
						Yes		Val-matic	2 inch – 12 inch series 5000.3XF and 14 inch to 36 inch series 5000F.3XF	
			-	-	-	Yes	-	Mueller Company	<u>Milliken Valve Company</u> Ballcentric Plug Valves	
			-	-	-	Yes	-		<u>Henry Pratt Company</u> Ballcentric Plug Valves	
			-	-	-	Yes	-	Dezurik	PEF	


◊ - PRC approval of a product will not be given, or considered, as part of an active bid or bid review.
 ◊ - Where this list may conflict with the Technical Specifications, the Technical Specifications take precedence.
 ◊ - the use of these pre-approved products in some applications may require a Deign Exception.
 ◊ - When deemed to be in the best interest of the County, the County reserves the right to:
 1) remove a product from this list without notice, and 2) limit the number of pre-approved products or manufacturers

Hillsborough County Public Utilities Department Appendix B: Pre-approved Products and Materials

 Hillsborough County Florida			Optimal County Limit ☀	POTABLE WATER	RECLAIMED WATER	WASTEWATER (Gravity)	WASTEWATER (Force Main)	WASTEWATER (Pump Station)	Manufacturer	Part Name/ Model Number	Important Notes and Stipulations
Valves	Tapping Valves	4" to 12"	No Limit	Yes	Yes	-	Yes	Yes	M&H Valve Co. (McWane)	4751	Tapping valves for force mains are considered sacrificial and an additional plug valve is required.
				Yes	Yes	-	Yes	Yes	Clow Valve Co. (McWane)	F-6114	Tapping valves for force mains are considered sacrificial and an additional plug valve is required.
				Yes	Yes	-	Yes	Yes	Mueller Co.	T-2361 Series	Tapping valves for force mains are considered sacrificial and an additional plug valve is required.
				Yes	Yes	-	Yes	Yes	U.S. Pipe Company	T-USPO Series	Tapping valves for force mains are considered sacrificial and an additional plug valve is required.
				Yes	Yes	-	Yes	Yes	American Flow Control	2500 Series	Tapping valves for force mains are considered sacrificial and an additional plug valve is required.
	14" & larger	No Limit	Yes	Yes	-	Yes	Yes	American Flow Control	2500 Series	Tapping valves for force mains are considered sacrificial and an additional plug valve is required.	
			Yes	Yes	-	Yes	Yes	Clow Valve Co. (McWane)	F-6114	Tapping valves for force mains are considered sacrificial and an additional plug valve is required.	
			Yes	Yes	-	Yes	Yes	Mueller Co.	T-2361 Series	Tapping valves for force mains are considered sacrificial and an additional plug valve is required.	
			Yes	Yes	-	Yes	Yes	U.S. Pipe Company	T-USP1 Series	Tapping valves for force mains are considered sacrificial and an additional plug valve is required.	
			-	-	-	-	-			Tapping valves for force mains are considered sacrificial and an additional plug valve is required.	
Fire Hydrants	5	Yes	-	-	-	-	American Flow Control	B-84-B-5	304 Stainless Steel required on hydrant external and bonnet internal hardware and extension kit hardware.		
		Yes	-	-	-	-	Clow Valve Co. (McWane)	Medallion F-2545 (EcoBrass)	304 Stainless Steel required on hydrant external and bonnet internal hardware and extension kit hardware.		
		Yes	-	-	-	-	Kennedy Valve Company (McWane)	Guardian K81D	304 Stainless Steel required on hydrant external and bonnet internal hardware and extension kit hardware.		
		Yes	-	-	-	-	Mueller Co.	Super Centurion (A-423)	304 Stainless Steel required on hydrant external and bonnet internal hardware and extension kit hardware.		
		Yes	-	-	-	-	U.S. Pipe Valve & Hydrant Company (Mueller)	Metropolitan (M-94)	304 Stainless Steel required on hydrant external and bonnet internal hardware and extension kit hardware.		
		-	-	-	-	-					

◊ - PRC approval of a product will not be given, or considered, as part of an active bid or bid review.
 ◊ - Where this list may conflict with the Technical Specifications, the Technical Specifications take precedence.
 ◊ - the use of these pre-approved products in some applications may require a Design Exception.
 ◊ - When deemed to be in the best interest of the County, the County reserves the right to:
 1) remove a product from this list without notice, and 2) limit the number of pre-approved products or manufacturers

Hillsborough County Public Utilities Department Appendix B: Pre-approved Products and Materials

		Optimal County Limit ☀	POTABLE WATER	RECLAIMED WATER	WASTEWATER (Gravity)	WASTEWATER (Force Main)	WASTEWATER (Pump Station)	Manufacturer	Part Name/ Model Number	Important Notes and Stipulations	
			Yes	Yes	-	-	-				
Miscellaneous	Automatic Meter Reader (AMR) Meter Register	3	Yes	Yes	-	-	-	Transparent Technologies (T ²)	Innov8		
	Compound Pressure Gauges Assembly	No Limit	-	-	-	-	Yes	Ashcroft (Gauge)	25-1009-SWL-02L-XGV-Specify Desired Pressure Range (Silicone Filled)	Must have Ashcroft Diaphragm Seal (50-310SS-02T-XCK) Silicone Filled. If a larger gauge is needed such as the 45, the type 100 diaphragm seal is required.	
	<u>Automatic Flushing Systems</u> Use only as requested by HC-PUD: Careful analysis of cross connection prevention, storm water system surcharge, grounding, and dechlorination requirements must be considered at each proposed site.	No Limit	Yes	-	-	-	-	Hydro-Guard	HG-1, HG-2, HG-5, and HG-6	Use air gap backflow prevention models. Notify fire department when HG-6 is in use.	
		No Limit	-	-	-	-	-				
		No Limit	-	-	-	-	-				
	Wet Well Washer and Wastewater Conditioner	No Limit	-	-	-	-	Yes	Anue	EP-1300 Series	Grinder stations not included. Used only in special conditions. Requires HCWRD Engineering Approval.	
	Manhole Inserts	HDPE (Can only be used Off-Pavement)	No Limit	-	-	Yes	-	-	USSI	Inflow Defender	Structural ribbing, no vent, woven nylon handle, 304 SST hdwe, neoprene gasket
		304 SST (Collector & Arterial Roads)	No Limit	-	-	Yes	-	-	Contractor Specialties & Supply Co	No Flow In Flow	No vent, 304 SST handle and hdwe, neoprene gasket
			No Limit	-	-	Yes	-	-	Sealing Systems Incorporated (SSI)		No vent, 304 SST handle and hdwe, neoprene gasket
			No Limit	-	-	Yes	-	-	Inflow Systems, Inc.	Inflow Shield	No vent, 304 SST handle and hdwe, neoprene gasket
			No Limit	-	-	Yes	-	-	Southwestern Packing & Seals	Rainstopper	Vent, 304 SST handle and hrdwr, synthetic elastomer (EL) gasket
	Valve Stem Alignment	Not Required	No Limit	Yes	Yes	-	Yes	Yes	EMMA Sales LLC	BoxLoc	Recommended, but Not Required

◊ - PRC approval of a product will not be given, or considered, as part of an active bid or bid review.
 ◊ - Where this list may conflict with the Technical Specifications, the Technical Specifications take precedence.
 ◊ - the use of these pre-approved products in some applications may require a Deign Exception.
 ◊ - When deemed to be in the best interest of the County, the County reserves the right to:
 1) remove a product from this list without notice, and 2) limit the number of pre-approved products or manufacturers